

33534

Micrologic 7,0 A jedinica za prekid – LSIV – za NS
630b..1600 zračni



Glavno

Range of product	NS630b...1600
Product or component type	Control unit
Range compatibility	Compact NS630b...1600
Device application	Distribution
Poles description	3P 4P
Protected poles description	3t 3t + N/2 4t
Network type	AC
Network frequency	50/60 Hz
Trip unit name	Micrologic 7.0 A
Trip unit technology	Electronic
Trip unit protection functions	Selective + earth-leakage protection
Trip unit rating	630 A (50 °C) 800 A (50 °C) 1000 A (50 °C) 1250 A (50 °C) 1600 A (50 °C)
Protection type	Earth leakage Instantaneous short-circuit protection Overload protection (long time) Short time short-circuit protection
Earth-leakage protection	With

Komplementarno

Mounting mode	Drawout
Long time pick-up adjustment type Ir	Adjustable
Long time pick-up adjustment range	0.4...1 x In
Long time delay adjustment type	Adjustable 9 settings
[tr] long-time delay adjustment range	0.7...16.6 s 7.2 x Ir 0.7...24 s 6 x Ir 12.5...600 s 1.5 x Ir
Thermal memory	20 mn
Short-time pick-up adjustment type Isd	Adjustable 9 settings
[Isd] short-time pick-up adjustment range	1.5...10 x Ir
Short-time delay adjustment type	Adjustable 5 settings
[tsd] short-time delay adjustment range	0.02...0.5 s
Instantaneous pick-up adjustment type Ii	Adjustable
Instantaneous pick-up adjustment range	2...15 x In Off
Zone selective interlocking ZSI	With
Residual earth-leakage sensitivity adjustment type	Adjustable 9 settings
[IΔn] residual earth-leakage sensitive adjustment	0.5...30 A
Residual earth-leakage time delay adjustment type	Adjustable 5 settings
[Δt] residual earth-leakage time delay adjustment	60...1000 ms
Display type	Digital display
Type of measurement	Ammeter

Okolina

Informacije dane u ovoj dokumentaciji sadrže opće opise i/ili tehničke karakteristike o performansama ovdje sadržanih proizvoda.
Ova dokumentacija nije namijenjena kao zamjena za niti bi se trebala koristiti za određivanje prikladnosti ili pouzdanosti predmetnih proizvoda za konkretne korisničke primjene.
Svaki takav korisnik ili integrator dužan je provesti odgovarajuću i potpunu analizu rizika, procjenu i ispitivanje proizvoda u odnosu na odgovarajuću specifičnu primjenu ili uporabu istog.
Niti društvo Schneider Electric, Industries SAS niti bilo koje od njegovih povezanih poduzeća ili podružnica neće preuzeti obvezu ili snositi odgovornost za pogrešnu upotrebu ovdje sadržanih informacija.

Contractual warranty

Warranty period	18 months
-----------------	-----------
