



### Glavno

|                             |   |
|-----------------------------|---|
| Cabling installation system | Floor box   |
| Product or component type   | Altira floor outlet box                           |
| Type of floor               | In-cavity floor<br>Raised floor<br>Screeded floor |
| Floor box shape             | Square  |
| Colour tint                 | Grey RAL 7011                                     |
| Quantity per set            | 1 piece   |

### Komplementarno

|                   |                        |
|-------------------|------------------------|
| Number of modules | 4 modules              |
| Material          | PA6<br>PC/ABS<br>Steel |
| Length            | 199 mm                 |
| Height            | 72 mm                  |
| Width             | 199 mm                 |

### Okolina

|                                       |   |
|---------------------------------------|---|
| standards                             | 73/23/EEC<br>93/68/EEC<br>IEC 61084-1: ed. 1, 1991<br>IEC 61084-2-2: 2003 |
| ambient air temperature for operation | -25...60 °C   |
| IP degree of protection               | IP20  |

### Offer Sustainability

|   |   |
|---|---|
| Green Premium product   | Green Premium product   |
| Compliant - since 0701 - Schneider Electric declaration of conformity | Compliant - since 0701 - Schneider Electric declaration of conformity |
| Reference not containing SVHC above the threshold                     | Reference not containing SVHC above the threshold                     |
| Available   | Available   |
| Need no specific recycling operations                                 | Need no specific recycling operations                                 |

### Contractual warranty

|                 |           |
|-----------------|-----------|
| Warranty period | 18 months |
|-----------------|-----------|

Informacije dane u ovoj dokumentaciji sadrže opće opise i/ili tehničke karakteristike o performansama ovdje sadržanih proizvoda. Ova dokumentacija nije namijenjena kao zamjena za niti bi se trebala koristiti za određivanje prikladnosti ili pouzdanosti predmetnih proizvoda za konkretne korisničke primjene. Svaki takav korisnik ili integrator dužan je provesti odgovarajuću i poipunu analizu rizika, procjenu i ispitivanje proizvoda u odnosu na odgovarajuću specifičnu primjenu ili uporabu istog. Niti društvo Schneider Electric Industries SAS niti bilo koje od njegovih povezanih poduzeća ili podružnica neće preuzeti obvezu ili snositi odgovornost za pogrešnu upotrebu ovdje sadržanih informacija.