

Podatkovni list proizvoda

Karakteristike

XVDL35

neprekidni narančasti signalni semafor XVD – BA 15d
baza – 250 V maks. – IP 40



Glavno

Range of product	Harmony XVD Application
Product or component type	Beacon
Beacon or indicator bank unit type	Base unit Illuminated unit
Signalling type	Steady
Mounting diameter	70 mm
Component name	XVD
Material	Glass reinforced polyamide (base unit) Polycarbonate (illuminated unit)
Light source	Orange bulb not included
Bulb type	Incandescent with BA 15d Protected LED
[Us] rated supply voltage	<= 250 V
Power dissipation in W	<= 10 W

Komplementarno

Assembly style	Customer assembly
Connections - terminals	Screw clamp terminals, connection capacity: <= 1 x 1.5 mm ² with cable end
[U _i] rated insulation voltage	250 V conforming to IEC 60947-1
Nominal voltage limit	0.85...1.1 U _n conforming to IEC 60947-5-1
[U _{imp}] rated impulse withstand voltage	4 kV conforming to IEC 60947-1
CAD overall width	70 mm
CAD overall height	133 mm
CAD overall depth	70 mm
Terminals description ISO n°1	(COM-1)PW (GND)GROUND
Product weight	0.255 kg

Okolina

pollution degree	2
product certifications	CSA GOST UL
standards	EN/IEC 60947-5-1
protective treatment	TC
ambient air temperature for operation	-25...50 °C LED -25...70 °C incandescent
ambient air temperature for storage	-40...70 °C
electrical shock protection class	Class I (on support tube, with metal fixing plate) conforming to IEC 60536 Class II (on base unit) conforming to IEC 60536 Class II (on support tube, with plastic fixing plate) conforming to IEC 60536
IP degree of protection	IP40 conforming to IEC 60529


Contractual warranty

Warranty period	18 months
-----------------	-----------

Informacije dane u ovoj dokumentaciji sadrže opće opise i/ili tehničke karakteristike o performansama ovdje sadržanih proizvoda. Ova dokumentacija nije namijenjena kao zamjena za niti bi se trebala koristiti za određivanje prikladnosti ili pouzdanosti predmetnih proizvoda za konkretne korisničke primjene. Svaki takav korisnik ili integrator dužan je provesti odgovarajuću i potpunu analizu rizika, procjenu i ispitivanje proizvoda u odnosu na odgovarajuću specifičnu primjenu ili uporabu istog. Niti društvo Schneider Electric Industries SAS niti bilo koje od njegovih povezanih poduzeća ili podružnica neće preuzeti obvezu ili snositi odgovornost za pogrešnu upotrebu ovdje sadržanih informacija.

Customer Assembled Beacon with Steady or Flashing Light Signalling

Dimensions



Customer Assembled Beacons and Indicator Banks

Wiring Diagrams

