



Glavno

| | |
|------------------------------------|--|
| Range of product | Harmony XVD Optimum |
| Product or component type | Complete miniature beacon |
| Beacon or indicator bank unit type | Base unit with direct fixing mode Illuminated unit |
| Signalling type | Flashing |
| Mounting diameter | 45 mm |
| Component name | XVDLS |
| Material | Glass reinforced polyamide (base unit) Polycarbonate (illuminated unit) |
| Light source | Yellow integral flash discharge tube |
| Bulb type | Flash discharge tube |
| [Us] rated supply voltage | 230 V AC |

Komplementarno

| | |
|---|---|
| Connections - terminals | Screw clamp terminals, connection capacity: $\leq 1 \times 1.5 \text{ mm}^2$ with cable end |
| Cable entry | 1 entry tapped for Pg 7 |
| [U _i] rated insulation voltage | 250 V conforming to IEC 60947-1 |
| Current consumption | < 25 mA AC |
| [U _{imp}] rated impulse withstand voltage | 4 kV conforming to IEC 60947-1 |
| Flash energy | 1 J |
| CAD overall width | 45 mm |
| CAD overall height | 104 mm |
| CAD overall depth | 45 mm |
| Terminals description ISO n°1 | (COM-1)PW (GND)GROUND |
| Product weight | 0.085 kg |

Okolina

| | |
|-------------------------------------|----------------------------------|
| product certifications | CSA UL |
| standards | EN/IEC 60947-5-1 |
| protective treatment | TC |
| ambient air temperature for storage | -40...70 °C |
| electrical shock protection class | Class II conforming to IEC 60536 |
| IP degree of protection | IP40 conforming to IEC 60529 |


Contractual warranty

| | |
|-----------------|-----------|
| Warranty period | 18 months |
|-----------------|-----------|

Illuminated Beacon

Dimensions

Informacije dane u ovoj dokumentaciji sadrže opće opise i/ili tehničke karakteristike o performansama ovdje sadržanih proizvoda. Ova dokumentacija nije namijenjena kao zamjena za niti bi se trebala koristiti za određivanje prikladnosti ili pouzdanosti predmetnih proizvoda za konkretne korisničke primjene. Svaki takav korisnik ili integrator dužan je provesti odgovarajuću i potpunu analizu rizika, procjenu i ispitivanje proizvoda u odnosu na odgovarajuću specifičnu primjenu ili uporabu istog. Niti društvo Schneider Electric Industries SAS niti bilo koje od njegovih povezanih podružnica neće preuzeti obvezu ili snositi odgovornost za pogrešnu upotrebu ovdje sadržanih informacija.



Illuminated Beacon

Panel Cut-out for Direct Fixing

